

High Expansion Foam System Requirements for CMS and ATLAS

General rules according to NFPA 11A and Règle APSAD R12:

- 1) All piping to each foam generator shall be subjected to a 2-hours hydrostatic test at 200psi or 50 psi in excess of the maximum pressure anticipated, whichever is greater. (NFPA 11A- 1-8.4.2)
- 2) Inspection and tests at least annually by a competent engineer inspector. (NFPA 11A- 1-13.1)
- 3) The minimum total depth of foam shall be not less than **1.1** times the height of the highest hazard but in no case less than 0.6 m over this hazard. (NFPA 11A- 2-3.2.1). In our case we will take **1.1**
- 4) Compensation factor (C_N) for normal foam shrinkage shall be **1.15** (NFPA 11A- 2-3.5.2) if no other experimental values are available, but from J.Fivet tests we got a factor $C_N =$ **1.4**
- 5) Compensation factor (C_d) for foam destruction by heat and smoke (this comes from CERN tests on polluted air at the fan inlet that can destroy the growing bubble of foam) shall be: **1.2**
- 6) Compensation factor (C_L) for loss of foam **1.2** (NFPA 11A- 2-3.5.2) for ATLAS that has a big free volume inside the muon chambers. For CMS previous calculations did not consider the trenches underneath the detector and took this factor equal to 1! I think also CMS should take **1.2**
- 7) The maximum flooding time should not exceed: **10 min**

According to those rules the total flow rate of foam needed should be calculated by the following equation:

$$D = (V/t) * C_N * C_d * C_L$$

CMS


Total Cavern volume
Volume above the fire denger height(25m*50m*2m)
Detector volume
Volume to be filled

Foam Flow rate: $D=(19000/10)*1.4*1.2*1.2$

D= 3326.4 m³/min

Most common High Expansion Foam have an expansion factor of **600**

Therefore the before the generation of the foam the flow rate should be of: **332.64 m³/h**



ATLAS


Volume of the cavern (24m*1.1*43m*30m)	34056 m ³
Various Equipment Volume	2500 m ³
Detector volume	13500 m ³
Volume to be filled	18056 m³

Foam Flow rate: $D=(19000/10)*1.4*1.2*1.2$

$$D= 3640.1 \text{ m}^3/\text{min}$$

Most common High Expansion Foams have expansion factor of : 600

Therefore the before the generation of the foam the flow rate should be of: 364.01 m³/h



Water flow rate needed

The various firms are usually working with proportioning ratio ranging between 2 and 3 % . This is the percent of concentrated foam liquid in water. Considering the most critical case (2%) that is the one requiring the largest amount of water we come to: the following flow rates needed :

CMS: 325.99 m³/h

ATLAS: 356.73 m³/h

Pressures needed

The highest the pressure is the best it is! A pressure of 8 bar at the inlet of each foam generator seems to be the best compromise for most of the firms but can fulfill our flow rates requirements also with 6 bar. Others firms are requiring a maximal pressure of 6 bar.

- SOLUTIONS
- 1) If the water comes from the surface the 100 m water column give enough pressure to provide the solution at 8 bar
 - 2) If the LHC uncutted line is provided at 6 bar but in the underground a pump is needed.

Pressure drop Calculation for solution 1):

ATLAS:

- 6 bar driving pressure in the water line.
- 1 bar of pressure drop between inlet and outlet of the bladder (still to be decided if it will be in SD1 or US15)
- 0.4 bar of pressure in 120m (from surface to underground) of 300mm (ID) pipe (already installed!)
- 9 bar of hydrostatic pressure on 90m of fall
- 2 bar of pressure drop in 30m of 170mm pipe between the bladder (or 300mm pipe in US15) and the branching in UX15.
- 3.3 bar of pressure drop in each one of the two branches of different diameter to have equal flow in the two lines.
Each line is 30 m long and the pipes diameter is 120mm.
- 1.3 bar in the two final sections. Each one of these section is composed by a main pipe (20m of 110 mm pipe)
and the four branches feeding the blowers (two/corner, 2m long and 80 mm)

TOTAL 7 bar at each fan inlet